

DRAFT

9

WASTEWATER

This chapter provides ordinance, policy, and standards establishing minimum design criteria for the modification and construction of wastewater systems to be owned and operated by the City of Scottsdale. It is intended for use in the planning, design, and the preparation of final plans.

Water Resources

9388 E San Salvador
480-312-5685

Water Operations

8787 E Hualapai Drive
480-312-8732

Water Quality

8787 E Hualapai Drive
480-312-8732

Plan Review

7447 E Indian School Road
Suite 105
480-312-7938

One Stop Shop

7447 E Indian School Road
Suite 100
480-312-2500

DRAFT

contents

Sections_____

- 9.000 General Information
- 9.100 Agreements
- 9.200 Design Reports
- 9.300 Wastewater Facilities
- 9.400 Collection System
- 9.500 Final Plans Preparation Requirements

Figures_____

- 9-A
- 9-B
- 9-C

WASTEWATER

GENERAL COMMENTS

9.000

A. Ordinance Requirements

Developers shall install, at their expense, all improvements necessary to provide wastewater service to their development. This shall include any sanitary sewer lines, lift stations, force mains, or other facilities, and the payment of all required development fees (sec. 49-73).

There is established a program for extension of the City's wastewater system to newly developed areas and subdivisions inside the City's service area, for which City wastewater service is desired and available (sec. 49-212).

B. Design Policy

A civil engineer registered in the State of Arizona is required to analyze the wastewater generation from a proposed development and determine its' impact on the City's wastewater collection system. This analysis is typically required from the development to a point on the downstream system where the engineer can certify compliance with a master plan previously accepted by the City. The City is responsible for analysis of sanitary sewer lines shown in the City's Wastewater System Master Plan.

EPA REGULATIONS

9.001

The City is required by the United States Environmental Protection Agency to develop and implement a program to control discharges that might harm the Publicly Owned Treatment Works (POTW). The program establishes local discharge limits for non-residential users and provides for a permitting process based on the users discharges and type of business. Details of the program and requirements are found in Article IV of Chapter 49 (Water, Sewers and Sewage Disposal) of the Scottsdale Revised Code. Specific information may be obtained by calling the Water Resources Department.

ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY REQUIREMENTS

9.002

A. Design Policy

Maricopa County Environmental Services Department (MCESD) is required to review and approve all public sanitary sewer line extensions and construction of related wastewater facilities within the City's service area, prior to the City approving the final plans.

Engineering Bulletin No. 10, "Guidelines for the Construction of Water Systems" published by the Arizona Department of Environmental Quality, and Arizona Administrative Code, "Title18 - Environmental Quality", contain specific requirements for submittals, approvals, and notifications when extension of a public sanitary sewer line is proposed. Some of the provisions of these documents are outlined below. It shall be the responsibility of the developer to read and comply with these regulations and requirements.

1. Prior to approval of final plans by the City's Plan Review Services, the developer shall submit a cover sheet for the improvement plans with a completed signature and date of approval from the MCESD.
2. Before commencing construction, the contractor or developer shall provide documentation to the City public works inspector that a Certificate of Approval to Construct and/or Provisional Verification of General Permit Conformance has been approved by MCESD.
3. Before building permits are issued, the developer shall submit to the City public works inspector a Certificate of Approval of Construction and/or Verification of General Permit Conformance signed by MCESD.
4. Prior to the City's Inspection Services issuing a Letter of Acceptance, the developer shall deliver to the City's Public Works Inspector an acceptable set of full-size four (4) mil as-built mylars of the improvements.

9.003**PRIVATE WASTEWATER COMPANIES**

Portions of Scottsdale's municipal service area are provided sewage disposal service by private wastewater companies. Figure 9-1 delineates these areas.

Placement of private sanitary sewer lines within City right-of-way requires an agreement between the private wastewater company and the City.

The private company should review modifications or construction of wastewater systems within their franchise areas. The developer shall submit, with final plans to the City, written documentation that the private wastewater company has reviewed and approved the sanitary sewer lines within their jurisdiction. The City cannot provide wastewater service within private wastewater company franchise areas, and will not review private wastewater systems unless requested by the owner, or for work that is to occur within the City's right-of-way. In cases where the City is requested to review private wastewater systems, the applicable review fees must be paid. A note shall be placed on the drawings stating operation and maintenance responsibilities.

9.100**AGREEMENTS**

Developers and property owners who install improvements to the public wastewater system may be eligible to request a credit, oversize, or payback agreement with the City allowing for partial reimbursement of costs to design and construct those improvements.

9.101**CREDIT AGREEMENTS**

Credit agreements are established to compensate a developer for installing system infrastructure that has been identified in the City's Capital Improvement Plan and/or included in the most recent Development Fees Report. Credit agreements are set up through the Water Resources Department and are to be identified in the developer's master plan.

9.102**OVERSIZE AGREEMENTS**

Oversizing Agreements will allow the City to compensate developers for the cost to install a sanitary sewer line larger than what is minimally required to serve the development. Oversizing is requested by the Water Resources Department determines when it determined that a larger line is necessary to meet the needs of additional properties upstream of the development. All oversizing projects involving City funds must have an oversizing agreement, and must meet all City requirements prior to plan approval and

construction. The City can only participate in the cost of oversizing provided there are sufficient funds in the capital improvements budget, and the amount does not exceed the limitations set forth by the Arizona Revised Statutes, Title 34, Article 2, Paragraph 201.D. If sufficient funds do not exist, the oversized lines will be installed at the developer's cost. Oversizing agreements are set up through the Water Resources Department. For specifics on oversizing agreements, Contact the Water Resources Department.

PAYBACK AGREEMENTS

Developers may request a Payback Agreement when they construct sanitary sewer lines across frontages of parcels not currently receiving wastewater service from the City. When a designated parcel requests wastewater service, a prorated cost of the sanitary sewer line is collected by the City and returned to the developer. For questions or details on procedures to initiate an agreement, contact the Water Resources Department.

9.103

WASTEWATER SERVICE AGREEMENT

The County's Sewer Service Agreement form is to be completed by the engineer and submitted along with the final plans to the One Stop Shop. Plan Review Services signs for the water and wastewater portions of the agreement and Solid Waste Management Division signs for the refuse service. It is the owner's responsibility to obtain these signatures from the respective city divisions. The agreements will not be signed prior to the City approving the final plans. Following is specific information regarding the City's municipal wastewater system and the appropriate identification numbers:

System Name: City of Scottsdale Water Campus
Address: 8787 E. Hualapai Dr., Scottsdale, AZ 85255

Water Campus – Wastewater Treatment # 37-024
Gainey Ranch – Wastewater Treatment # 37-160

The following identification number relates directly to that portion of the City's wastewater system that is not treated at the Water Campus or Gainey Ranch. This area is generally south of Doubletree at Scottsdale Road, south of Via Linda at Pima Road, and excludes the Hayden corridor to Frank Lloyd Wright Blvd:

General sanitary sewer collection system # 37-011

The City's Wastewater System Master Plan is helpful in determining the appropriate system identification facility number. Questions should be directed to the Water Resources Department.

9.104

DESIGN REPORTS

Wastewater master plans and basis of design reports shall provide an analysis of the impact that a development will have on the City's wastewater system. These reports are reviewed and accepted by the Water Resources Department and then utilized by Plan Review Services to verify the infrastructure to be constructed. Accepted design reports are retained in the City's Records Department and are made available to developers and engineers upon request.

A. Design Policy

A civil engineer registered in the State of Arizona shall analyze all proposed development that is determined by the City to have an impact on the wastewater system. The effects of

9.200

peak flow will be examined to ensure proper sizing and layout of the proposed wastewater system facilities.

A wastewater master plan or a wastewater basis of design report is required for each development within the City when an extension of the system is necessary, or the proposed development will produce more than 10,000 gallons of wastewater per day. Water Resources staff will determine which report is appropriate for a given development and convey this requirement to the City's project coordinator for inclusion in the case's stipulations. Reports shall be separately submitted for review to the One Stop Shop, directed to the attention of the Water Resources Department. The reports shall be reviewed and accepted by the Water Resources Department prior to the submittal of final plans for review by Plan Review Services unless otherwise agreed to by Plan Review Services.

9.201**WASTEWATER MASTER PLAN**

A Wastewater Master Plan is required when a change in the existing zoning or land use is proposed, phased construction is proposed, or conditions where the Water Resources Department determines one is necessary.

The objectives of a master plan are to demonstrate that the proposed wastewater system complies with the most recent update of City's Wastewater System Master Plan, show compliance with the City's design criteria and development policies for each phase of the project, and establish a skeletal system for the phased development of a master planned project.

9.202**BASIS OF DESIGN REPORT**

Most projects within the City will require a Basis of Design Report. The objective of a basis of design report is to determine the development's wastewater demand and analyze the hydraulics of the proposed sanitary sewer system to a point evaluated by the City's Wastewater System Master Plan, and demonstrate conformance for each phase of a master planned development with the accepted master plan for that development.

9.203**GENERAL REPORT REQUIREMENTS**

All reports submitted to the City for review shall be prepared in accordance with the guidelines listed below.

A. General format

1. Letter sized paper (8 ½ x 11).
2. One-inch margins on all sides.
3. Bound along the left edge.
4. All reports shall have a table of contents.
5. Maps and other supporting materials larger than folded ledger size paper (11 x 17) shall be placed into sleeves providing an appendix to the report.
6. A civil engineer licensed to practice in the State of Arizona shall seal each report.

B. Report cover

1. Hard stock paper or better.
2. Project name.
3. Names addresses and phone numbers of the developer/owner and engineer.
4. Original submittal and any subsequent revision dates.

C. Vicinity map

1. Identify the project's location with respect to major cross streets.
2. Identify all major existing and proposed developments within a one-mile radius.

WASTEWATER BASIS OF DESIGN REPORT CONTENT**9.204****A. Introduction**

Summarize the proposed development:

1. Include a legal description based on sectional breakdown or reference within a platted development.
2. Describe the existing and proposed site zoning and land uses.
3. Include reference to elements of the City's General Plan and identify any designated character area or studies that will affect the project's design.

B. Design Documentation

Reference compliance with the City's Design Standards and Policies Manual, latest revision, and all other applicable design standards and codes.

1. Include a discussion of which design procedures, policies, and methodologies will be incorporated into the design engineering of the wastewater system.
2. List title and version of any software used in the design analysis.

C. Existing Conditions

1. State the existing zoning and land use.
2. Describe the existing, topography, vegetation, and landform features.
3. Include the location and description of existing utilities in the vicinity.
4. Reference any existing master plans or design reports applicable to adjacent development.
5. Indicate the results of any certified flow testing of the existing system.

D. Proposed Conditions

1. Include a site plan that indicates the layout of the proposed development.
2. Describe the proposed connection(s) to the City's wastewater system. Show extension of sanitary sewer lines into the site.
3. Address maintenance responsibilities of the proposed wastewater system.

E. Computations

1. Wastewater flows shall be based upon the design flows in this manual
2. Any variance from the stated design flows should be verified with the Water Resources Department.
3. Particular attention shall be given to wastewater peaking factors used for restaurants or specialty developments.
4. Scour analysis where surface runoff exceeds five hundred (500) cfs over a sanitary sewer pipe.

F. Design Documentation

1. Electronic copies of all computer calculations for the wastewater analysis shall be submitted along with the final report.
2. Common spreadsheet formats shall be compatible with MS Excel.

G. Summary

1. Provide a summary of the proposed wastewater improvements stating that all the City's design standards and policies have been met or indicate any variance or exception. Note why the developer is requesting any variance or exception.
2. Include a brief project schedule indicating the proposed start and completion of the developments improvements.

H. Supporting Maps

Include a scaled site plan showing all existing and proposed utility lines and surface improvements.

1. Graphics shall screen the development's background, dash existing utilities, and present proposed utilities as bold solid lines.
2. Existing topography shall be screened into the background. All existing and proposed contour intervals shall be clearly labeled at two-foot intervals. Sufficient information to evaluate pipe cover must be shown.
3. All property lines, rights-of-way, tract, and easement lines shall be clearly shown, dimensioned, and labeled.

I. Miscellaneous

Requests for more specific information regarding report requirements and the wastewater system may be obtained by contacting the Water Resources Department.

9.205**WASTEWATER MASTER PLAN REPORT CONTENT**

1. The Wastewater Master Plan Report will specify the terms and requirements for wastewater service to the development.
2. All development projects shall be responsible for determining their specific wastewater discharge and shall include flow from any upstream developments to ensure the system is designed properly.
3. If the proposed development requires a change in zoning which increases density or proposes a wastewater system different from the City's existing Wastewater System Master Plan, then additional off-site calculations will be required.
4. Flows shall be calculated according to this section.
5. A computer disk containing all calculations shall be submitted along with the Master Plan report.
6. Each Master Plan map must show the following:
 - i. All proposed on-site and off-site facilities including, but not limited to, lift stations, trunk lines, and collection lines.
 - ii. Proposed street locations, parcel boundaries and proposed lots within each parcel.
 - iii. Contour lines at two-foot intervals showing the elevation of the land surface.
 - iv. A separate area location map shall be provided showing existing and proposed streets, as well as existing parcels surrounding the project to a distance of one mile from the exterior boundaries of the project. Assessor's maps can provide the information required to prepare these composite maps.
 - v. The scale of all maps must be sufficient to show all required information clearly.
7. All sanitary sewer lines that cross golf courses or other open areas must do so within established roads. If dedicated roads are not practical, then the crossing must be within twenty (20) foot wide accessible easement within a tract. No walls shall cross these easements.

8. The Wastewater Master Plan must show compliance to construct sanitary sewer lines, if not already in place, across all dedicated frontages of the development where future.
9. A construction schedule shall be included in a table format for all wastewater related construction required to serve the development. The schedule shall have each phase or parcel as column headings and each construction project or system component as right-of-way (ROW) headings. A mark in each box shall specify when each constructed item will be required for each phase of the development.
10. Compliance with the adopted City Wastewater System Master Plan encompassing the respective area.
11. Those Master Planned Developments that design a wastewater collection system that will be phased shall provide a description of the phasing.
12. For specific information regarding wastewater plan requirements and/or the City's current Wastewater System Master Plan, contact the Water Resources Department.

WASTEWATER FACILITIES

9.300

Lift stations and force mains are typically designed and constructed by the City through its' capital improvement program. Developers needing to construct these facilities shall contact the Water Resources Department and request a meeting. The developer should be prepared to address how the proposed system will conform to the City's Wastewater System Master Plan. The City will address design issues, the City's review process for wastewater facilities, and any potential City cost participation.

A. Ordinance Requirements

When wastewater service is not available, a septic system or alternative system acceptable to the Water Resources Department may be allowed with the approval of both the City of Scottsdale and the Maricopa County Environmental Services Department (sec. 49-116).

B. Design Policy

Maricopa County Environmental Services Department and the City discourage the development of privately owned packaged treatment facilities designed to serve two or more lots.

Wastewater lift stations and force mains required to serve a development that will not provide service to adjacent properties and will provide service to less than thirty (30) lots shall be considered private and shall be maintained by the home owners association and/or property owners association. The wastewater collection system within the development upstream of the lift station must also be a private system.

SEPTIC SYSTEMS / ONSITE WASTEWATER TREATMENT FACILITIES

9.301

Design, construction, operation, and maintenance of septic systems / onsite wastewater treatment facilities are responsibilities of the property owner. The City will not accept any type of onsite system for operation and maintenance.

All onsite wastewater treatment facilities shall be designed and constructed compliant with the applicable requirements of the Maricopa County Environmental Services Department. Final plans submitted to the City's One-Stop Shop shall include the County's permit number for the onsite system.

9.302**WASTEWATER LIFT STATIONS**

Water Operations maintains a separate document outlining the design, specifications, and materials required for a City owned and maintained wastewater lift station. Contact the Water Resources Department for current information.

A. Site Selection

In selecting a site for a sewage lift station, consideration should be given to accessibility, drainage patterns, visual impact, function, and design constraints.

The potential for flooding should be considered when selecting a pump station location.

The station's equipment shall be protected from damage and remain operable during a one hundred (100) year flood.

Unless otherwise agreed to in writing by the City's Right-of-Way Agent, each tract or lot dedicated to the city shall be conveyed by a general warranty deed, and accompanied by a title policy in favor of the City, both to the satisfaction of City.

B. Lift Station Design

Arizona Administrative Code, Title 18, Chapter 9, "Water Pollution Control" contains minimum requirements for a wastewater lift station. Additional requirements specific to the City must be obtained from the Water Resources Department before beginning design. At a minimum, telemetry, dual pumps, backup power supply, three-phase power, odor control, and perimeter walls will be required. The site shall be large enough to contain all the equipment and service equipment for repairs.

Prior to the preparation of construction drawings, a preliminary basis of design report will be prepared and submitted to the One Stop Shop for Water Resources Department review.

The preliminary report shall outline the type of equipment and controls proposed for the station. A final basis of design report prepared by a registered professional engineer licensed in the State of Arizona must accompany all pump station design drawings submitted to the City for review.

9.303**FORCE MAINS**

Force mains shall be located within a right-of-way, private street tract, or utility easement. Line shall be located under pavement where possible.

A. Velocity Requirements

The flow velocity in the force main shall be between four (4) and six (6) fps.

B. Materials of Construction

All pipe material used in design of the force mains shall have established ASTM, ANSI, AWWA, and NSF standards of manufacture, or seals of approval, and shall be designated as pressure sanitary sewer pipe. Force mains shall be identified as such with marking tape one (1) foot above the pipe.

C. Air Release Valves

Air release valves designed for sewage shall be provided on force mains at all peaks in elevation. See City of Scottsdale Standard Detail No. 2405.

D. Cleanouts

Two-way cleanouts shall be provided every one thousand three hundred (1,300) feet apart or one-way cleanouts every six hundred fifty (650) feet. See City of Scottsdale Standard Detail No. 2403.

E. Force Mains

Force mains shall be constructed of restrained ductile iron pipe for the following conditions:

1. At all locations where a vertical realignment is required.
2. Crossing of drainage washes.
3. Air release assemblies.
4. Clean-out assemblies.

F. Line Separations

1. Where a force main crosses a water main or transmission line, protection shall be provided as per ADEQ Engineering Bulletin No. 10 and the Arizona Administrative Code, Title 18, Chapter 9, "Water Pollution Control". At a minimum, the force main shall be constructed of ductile iron pipe for a distance of ten (10) feet on each side of the water line.
2. See City of Scottsdale Standard Detail No. 2402 for details regarding discharge into a manhole from a force main.
3. The minimum separation between the force mains and water lines shall be two (2) feet wall-to-wall vertically and six (6) feet horizontally under all conditions. Where a force main crosses above, or less than six (6) feet below a water line, the force main shall be encased in at least six (6) inches of concrete for ten (10) feet on either side of the water line.

The engineer shall evaluate the potential for odor to develop from a force main downstream of the receiving manhole. One-way valves on building service lines shall be specified where there is potential for gasses to strip from the waste stream. The valves should be located at or near the building cleanout for access and maintenance by the property owner.

COLLECTION SYSTEM

This section describes the minimum requirements for extension of the public wastewater collection system.

A. Ordinance Requirements

The City will require sanitary sewer lines to be installed along the entire length of property line frontage of the property being developed whenever future extension of the wastewater system is possible. The property line frontage is that portion of the property that abuts a street, public utility easement, or public right-of-way. If a parcel to be developed has more than one property line frontage, the City may require a sanitary sewer line to be installed along the entire length of all frontages (sec. 49-219).

Developers shall install, at their expense, all on-site and off-site improvements necessary to serve their development. This includes payment of all required development fees (sec. 49-73).

Onsite sanitary sewer lines to commercial shopping center developments are to be privately owned, operated, and maintained. Multifamily developments may elect to install public or private sanitary sewers (sec. 49-118).

When required by the City, users who discharge non-residential wastewater shall install monitoring manholes (sec. 49-96). Users discharging industrial wastes shall install monitoring manholes and provide written notice to the Water Resources Department (sec. 49-161).

B. Design Policy

When a public sanitary sewer line is located within six hundred sixty (660) feet of the boundary of the subject property, the line shall be extended to provide service to the property. A private onsite wastewater treatment system may be constructed only when a public wastewater system is not available.

9.400

Sanitary sewer lines shall not be privately owned if future connections to those lines would be necessary to serve adjacent parcels.

For planned developments and subdivisions where an existing sanitary sewer is not available, a dry sanitary sewer line shall be installed conforming to all the design requirements for a public sanitary sewer line. The capped ends of service line stubs on a dry system shall be located with a permanent marking system. Interim onsite wastewater treatment systems shall be designed for future connection to the dry system when sanitary sewer service becomes available.

Wastewater systems shall be designed to serve the ultimate population density expected in the tributary area. The design must be in conformance with the current City approved Wastewater System Master Plan and shall take into consideration future connections.

Where extension of a wastewater collection system is possible upstream of a subdivision, the sanitary sewer shall be extended through the subdivision to the platted boundary to provide for a point of connection that is desirable to provide wastewater service to adjacent properties.

C. Design Standards

The engineer should be familiar with the Maricopa Association of Government's Uniform Standard Specifications for Public Works Construction and the City of Scottsdale Supplement to MAG Uniform Standard Specifications for Public Works Construction, including all applicable Standard Details. These documents contain construction related specifications and details that impact the design of water systems including trenching, bedding, backfill, pavement replacement, etc.

9.401

MATERIALS

In selecting pipe material for sanitary sewer lines, consideration should be given to chemical characteristics of the wastewater (especially for industrial wastes), velocity, the possibility of septicity, external and internal pipeline forces, and preventing infiltration, abrasion, and similar problems.

Sanitary sewer lines shall be vitrified clay pipe (VCP), polyvinyl chloride (PVC) SDR35 up to fifteen (15) inches diameter, PVC meeting ASTM F679 - T1 between eighteen (18) and twenty-seven (27) inches diameter, or ductile iron pipe (DIP) with approved interior and exterior linings. Requests for consideration of alternative materials shall be submitted in writing to the Water Resources Department.

Pipe material shall not change between manholes.

Where standard strength pipe is not structurally sufficient due to external loading, or four (4) feet of pipe cover cannot be maintained, the engineer shall submit a written request, along with supporting calculations, to the Water Resources Department for permission to use extra-strength pipe, special bedding specifications, or alternative construction methods. The Water Resources Department must accept the request, in writing, prior to Plan Review Services approval of the final plans.

All types of pipe material used in design shall have established ASTM, ANSI, or NSF standards of manufacture or seals of approval and shall be designated for use as wastewater pipe.

9.402

SYSTEM LAYOUT

Generally, sanitary sewer lines constructed along a street grid shall be aligned parallel to, and south or west of, the street centerline. Lines should not cross the street centerline except in cases where curvilinear roadway alignments are encountered.

Public sanitary sewer lines within commercial, industrial, or multi-family developments shall be located within drive aisles a minimum of six (6) feet from any structure. Public sanitary sewer lines will be located within tracts and/or public utility easements. No private utilities are allowed longitudinally within a public utility easement.

If the horizontal direction, slope, material, or size of the sanitary sewer line changes, a manhole shall be constructed. The horizontal angle formed between the two lines shall not be less than ninety (90) degrees. In sanitary sewer lines that are twelve (12) inches or larger, angles formed shall be between one hundred-twenty (120) and one hundred-fifty (150) degrees to the downstream pipe, for odor control purposes.

Curvilinear sanitary sewer lines will not be allowed.

Wastewater flows shall not pass through collection systems that have not been accepted by the City.

Developments with numerous curved streets shall meet with the Water Resources Department to discuss whether the City will consider a design report with water and sewer layouts in accordance with the following criteria:

1. Water and sanitary sewer lines shall be placed under the paved section of the roadway within the area from back of curb to back of curb.
2. Sanitary sewer lines must maintain a minimum of three (3) feet horizontal clearance to dry utilities.
3. Sanitary sewer manholes are to be located at the approximate center of the drive lane.
4. The water line and sanitary sewer line shall run parallel to each other with nine (9) feet separation to centerline of the pipes in order to maintain six (6) feet clearance at manholes.

DESIGN FLOWS

A. Residential

Sanitary sewer lines eight (8) to twelve (12) inches in diameter shall be designed using one hundred (100) gallons per capita per day (gpcpd) and a peaking factor of four (4).

Sanitary sewer lines larger than twelve (12) inches in diameter shall be designed using one hundred five (105) gpcpd and a peaking factor developed from "Harmon's Formula":

$$Q_{\max} = Q_{\text{avg}} [1 + 14 / (4 + P^{1/2})]$$

Where P = Population / 1,000

Residential densities are to assume two and one-half (2.5) persons per dwelling unit, apartment, or town home.

B. Commercial and Industrial

Commercial and industrial flows shall be based upon known regional data or accepted engineering reference sources, approved by the Water Resources Department.

HYDRAULIC DESIGN

No public sanitary sewer lines shall be less than eight (8) inches in diameter unless permission is received in writing from the Water Resources Department.

Sanitary sewer lines should be designed and constructed to give mean full flow velocities of not less than two and one-half (2.5) fps, based upon Manning's Formula, using an "n" value of 0.013.

9.403

9.404

Conversely, to prevent abrasion and erosion of the pipe material, the maximum velocity shall be limited to 10 fps at estimated peak flow. Where velocities exceed this maximum figure, the line shall be constructed of DIP, and lined. In no case shall velocities greater than 15 fps be allowed.

Actual velocities shall be analyzed under peak flow conditions for each reach of pipe.

Generally, the sanitary sewer system shall be designed to achieve uniform flow velocities through consistent slopes. Abrupt changes in slope shall be evaluated for hydraulic jump.

The depth to diameter (d/D) ratio for gravity sanitary sewer pipes twelve (12) inches in diameter and less shall be no greater than 0.65 in the ultimate peak flow condition. The d/D ratio for gravity drains greater than twelve (12) inches diameter shall be no greater than 0.70 for the ultimate peak flow condition.

Mitigation of hydrogen sulfide shall be analyzed in the design report and be provided for in the design of the system.

9.405**MANHOLES AND CLEAN OUTS**

Manholes in City streets shall be located near the center of the inside traffic lane, rather than on or near the line separating traffic lanes. Manholes should not be located in bike trails, equestrian trails, sidewalks, crosswalks, or wash crossings. Manholes are required at all changes of grade, pipe size, pipe material, or alignment, and at distances not to exceed those shown below:

Pipe Diameter (inches)	Maximum Manhole Spacing (feet)
8 – 15	500
18 – 30	600
36 – 60	800
Over 60	1,300

A. Manhole Base

Manhole bases are to be cast in place. The flow channel through the manhole shall be steel trowel finished to conform in shape and slope to that of the sanitary sewer pipe. The manhole shelf shall be brush or broom finished, with a slope of one inch per foot. The manhole bottom should be filleted to prevent solids depositions and channeled to ensure satisfactory flow to the lower invert.

B. Manhole Sections and Cones

All manhole sections and cones shall be the precast concrete as detailed in the Maricopa Association of Governments Standard Detail No. 420, deleting the manhole steps and/or cast in anchors for steps.

If a manhole is more than ten (10) feet deep or the line is fifteen (15) inches in diameter or larger, the manhole shall be five (5) feet in diameter. Manhole depth shall be defined as the distance from the design rim elevation to the lowest invert elevation.

C. Manhole Covers

Manhole covers are to be per Maricopa Association of Governments Standard Detail No. 424.

D. Manhole Linings

Manholes shall be lined or coated when constructed on sanitary sewer lines fifteen (15) inches in diameter or larger, at the junction of a force main, or other design conditions

where corrosive conditions are anticipated. Manholes receiving wastewater from force mains and ejector lines shall be lined. Manholes requiring linings or coatings shall be noted on the final plans.

E. Intersecting Lines Within Manholes

Manholes shall be required for all lines intersecting at angles other than one hundred eighty (180) degrees, a change in slope, a change in pipe size, or a change in pipe material. The manhole shall have a minimum one-tenth (0.10) foot drop across the trough unless otherwise approved by the Water Resources Department. Where pipe size changes through a manhole, the top invert of the upstream pipe(s) shall be equal to or higher than the top invert of the downstream pipe. In large trunk lines, inverts at junctions should be designed to maintain the energy gradient across the junction and prevent backflow.

F. Drop Manholes

If the difference in invert elevations between inflow and outflow lines exceeds one pipe diameter, a drop connection shall be installed. Drop connections shall be in accordance with Maricopa Association of Governments Standard Detail No. 426, modified as follows:

1. For drops up to and including five (5), use Type "A" drop connections.
2. For drops greater than five (5) feet, use Type "B" drop connections.

The manhole bottom shall be filleted to prevent solid deposition.

G. Manholes at Washes and Drainage Areas

Manholes shall be protected from storm drainage and flooding conditions. Sanitary sewer lines will not be allowed in washes or drainage areas unless otherwise approved in writing by the Water Resources Department.

When approved by the City, manholes located within washes or drainage areas are to have bolted watertight covers to prevent inflow and the rim elevation shall be a minimum of eighteen (18) inches above adjacent finish grade (see City of Scottsdale Standard Detail No. 2420). The manhole base, barrel, and grade rings shall be designed to be watertight and the engineer shall provide structural protection against scour from a one hundred (100) year storm flow. This protection may require encasement of the entire manhole using sonotube form material, or the construction of a monolithic manhole. The manhole shall be designed by the engineer to meet the amount of protection as calculated by the flow conditions of the wash. The engineer is responsible to provide a manhole design eliminating infiltration in wash areas.

H. Cleanouts

Cleanouts per Maricopa Association of Governments Standard Detail No. 441 may be used in place of manholes at the ends of laterals that cannot be extended and are less than one hundred fifty (150) feet in length. Cleanouts are required to allow for maintenance and inspection of lines.

Service connections are not allowed at the ends of cleanouts. Service connections shall be provided off the sanitary sewer line a minimum of two (2) feet downstream of the cleanout.

MONITORING VAULTS AND MANHOLES

A. Monitoring Vaults

The Water Quality Division has sole discretion when to require a developer to install a monitoring vault for testing wastewater flow and composition. Generally, properties in industrial land use/zoned areas with a projected wastewater discharge of twenty-five thousand (25,000) gallons per day shall be required to install a monitoring vault per City of Scottsdale Standard Detail No. 2460.

9.406

B. Monitoring Manholes

The Water Quality Division has sole discretion when to require a developer to install a monitoring manhole. Generally, commercial properties with potential mixed uses, restaurants, and developments that will use chemicals or solvents are required to install monitoring manholes.

Monitoring manholes shall be constructed per Maricopa Association of Governments Standard Detail No. 420, with a straight channel and no taps or bends for twenty (20) feet upstream or downstream. Design details for monitoring manholes on sanitary sewer lines six (6) inches or larger with a peak flow greater than forty (40) gpm shall be approved by the Water Resources Department.

Monitoring vaults and manholes shall be located in a minimum sixteen (16) foot wide easement that extends from the manhole to the existing public wastewater system and be designed for access at all times to monitoring crews and vehicles.

9.407**PIPE COVER AND SEPARATIONS**

Sanitary sewer pipe shall be installed at a depth sufficient to ensure gravity drainage of wastewater from each service line and should anticipate the lowest potential finish floor elevation for each building pad.

Pipe design shall ensure gravity drainage from the ultimate drainage area, and shall allow for future extensions of service to adjacent parcels.

In no case shall sanitary sewer lines be installed with less than four (4) feet of cover over the top of the pipe unless otherwise approved by the Water Resources Department.

All sanitary sewer lines shall be designed to absorb superimposed live loads and backfill overburden without damage to the pipe material and without adversely affecting the hydraulic characteristics of the pipe. The Engineer shall specify minimum depths of cover to be provided during the construction of roadways or other facilities affecting cover over the line.

A. Separation of Water and Sanitary Sewer lines

Caution should be taken in the design and construction of the sanitary sewer lines to protect all water supplies from wastewater contamination. To minimize the potential of contamination, the engineer shall design the horizontal and vertical separation of water and sanitary sewer lines in accordance with Engineering Bulletin No. 10, "Guidelines for the Construction of Water Systems" published by the Arizona Department of Environmental Quality, and the Arizona Administrative Code, Title 18, Chapter 9, "Water Pollution Control".

The minimum horizontal distance from a water line to a sanitary sewer line shall be six (6) feet wall-to-wall. Minimum vertical clearance of a water line crossing over a sanitary sewer line is two (2) feet. Minimum vertical clearance of a water line crossing under a sanitary sewer line is eighteen (18) inches.

Where conditions prevent adequate vertical separation or where a water line must cross under a sanitary sewer line, both the water and sanitary sewer lines shall be constructed of ductile iron pipe (pressure class 350) with mechanical restraining joints.

The Water Resources Department may allow existing sanitary sewer lines to be encased in concrete, in lieu of replacement with ductile iron pipe, where the sewer line cannot be taken out of service.

B. Separation from Structures

Sanitary sewer lines shall have a minimum of six (6) feet horizontal clearance from any structural footing or substantial improvement. Design shall consider any structural load imposed on the pipe.

The Water Resources Department may consider the development of an indemnity agreement where no alternative sewer alignment is possible and surface improvements, including decorative paving or screen walls, are to be located within six feet of the sanitary sewer line. If an indemnity agreement is acceptable to the Water Resources Department, boilerplate language for an indemnity agreement will be provided with final plans review.

C. Separation from Other Utilities

See City of Scottsdale Standard Detail No. 2372.

D. Separation from Storm Drains and Culverts

Sanitary sewer lines crossing less than two (2) feet below a storm drain or culvert, or under large structures such as box culverts and bridges will require additional protection such as the use of ductile iron pipe or encasement. Sanitary sewer lines crossing over storm drains and culverts must be a minimum of one (1) foot above and be adequately protected.

WASH CROSSINGS

All wash crossings shall be constructed using restrained joint Class 350 ductile iron pipe. Bury requirements to place sanitary sewer lines under washes or channels shall be based upon the one hundred year peak design discharge (Q_{100}) in the channel or wash.

100 year flow rate	Minimum depth of bury
1 to 49 cfs	5 feet
50 to 99 cfs	5 feet
100 to 499 cfs	7 feet
Greater than 499 cfs	Scour depth based on scour analysis required

The minimum depth of bury below the design flow line of the channel or wash.

Wash crossings with a 100 year flow above five hundred (500) cfs shall have the scour depth estimated using Arizona State Standard Attachment SSA 5-96, Guideline 2, Level I, as published by the Arizona Department of Water Resources. The engineer shall estimate the depth of scour and design the top of pipe to be three (3) feet below the estimated scour depth. The engineer shall provide a detailed analysis of the scour depth with final plans for review and approval.

All pipelines that must be located within the scour zone, or with less than the minimum required depth of bury as indicated above, shall be protected by installing a cut-off wall downstream of the pipeline to stabilize the scour depth to a minimum of three (3) feet above the pipeline. Plan Review Services will review pipe protection and scour stabilization requirements on a case-by-case basis.

GRAVITY SANITARY SEWER SERVICE CONNECTIONS

The engineer shall make every effort to use existing sanitary sewer lines that have been stubbed out to a property by previous construction. Where the use of stubbed out lines is not feasible, the existing line will be abandoned and capped at the sanitary sewer main. If the existing service line is connected to a manhole, the trough of the manhole will be rebuilt to conform to the active lines.

9.408

9.409

A. Minimum diameters for service lines

Residential:	four (4) inch
Multi-family:	six (6) inch
Commercial:	six (6) inch

B. Installation

All service line connections shall be installed perpendicular to the sanitary sewer line in accordance with City of Scottsdale Standard Detail No. 2440, and extended to the back of the public utility easement and marked. Within the right-of-way or easement, no bends in the service line will be allowed.

C. Location

1. All proposed service line connections shall be shown on the final plans with stations and dimensions, or offsets, from street centerline. Typical separation dimensions from the water service lines shall be shown. Each lot or building must be provided with its own individual service line unless otherwise approved in writing by the Water Resources Department.
2. The service line location should be coordinated to avoid conflicts with other utilities, with driveway locations, and should be located within the downstream 1/3 of the fronting sanitary sewer line length.
3. Because water lines are located behind the curb in many locations, conflicts with sanitary sewer service lines are possible. Sanitary sewer lines should be designed to allow for the sanitary sewer service lines to pass under water lines with twelve (12) inches of vertical clearance to minimize potential health hazards.
4. When it is not possible to maintain sufficient vertical clearance, or the sanitary sewer service line will pass over the water main, the sanitary sewer service line must be encased in concrete of six (6) inches minimum thickness to six (6) feet from each side of the crossing, or ductile iron pipe must be used for the same distance. See Maricopa Association of Governments Standard Detail 404-2.

D. Requirements for Service Line Connection to Large Diameter Sanitary Sewer Lines

Sanitary sewer lines fifteen (15) inches in diameter, or larger, may be tapped only with a manhole. Service lines into manholes may be angled, but the flow line of the service line shall not be more than four (4) inches below the crown of the sanitary sewer line.

E. Requirements for Service Line Connections into Manholes on Small Diameter Sewer Lines

No more than four (4) service lines may be made into any manhole on a sanitary sewer line fourteen (14) inches in diameter, or smaller, without written approval from the City. Sanitary sewer service line inverts shall be not be more than one service line pipe diameter above the crown of the downstream sanitary sewer line in the manhole.

F. Service Line Connections at Cleanouts

Sanitary sewer service connections shall be located a minimum of two (2) feet downstream of the cleanout structure.

G. Maintenance

The property owner receiving wastewater service is responsible for maintenance of the sanitary sewer service line including the wye connection to the public main.

PRESSURIZED SANITARY SEWER SERVICE CONNECTIONS

Pressurized sanitary sewer ejector systems shall be owned, operated, and maintained by the property owner. The property owner's civil engineer is responsible for the design and hydraulic analysis of the pressurized system.

A. Connection of individual ejector to an adjacent gravity sanitary sewer line

The sanitary sewer service line constructed within the right-of-way will be per City of Scottsdale Standard Detail No. 2440. The pressurized line will connect into the gravity service line outside of the right-of-way and, if applicable, the adjacent public utility easement. Connection to the gravity service line will be at a cleanout connection.

B. Connection of individual ejector(s) downstream of a property

The City does not support extending private pressurized ejector lines across the frontages of adjacent lots or properties. The developer or property owner shall request a meeting with the Water Resources Department to discuss available options. One potential option is for the developer or owner to design and construct a segment of a public gravity collection system within the public right-of-way, or private street tract, and a lift station at the low terminus of the segment.

Where Water Resources approves the extension of individual private ejector lines across the frontages of adjacent properties:

1. Private manholes receiving wastewater from ejector lines and the first downstream public manhole shall be coated or lined to prevent corrosion.
2. Individual ejector lines from parcels shall be run within a private sewer easement, adjacent to any public right-of-way and utility easement. Spare conduits shall be provided, and clearly labeled on a plan detail, in the event a line becomes plugged or damaged.
3. Where individual ejector lines exceed six hundred (600) feet in length or have retention times exceeding three (3) hours, the engineer shall evaluate the potential for odor problems. The City will not accept odor-absorbing materials in basket containment, placed within manholes. Odor management will be incorporated through the use of biofiltration processes.

GREASE, OIL, AND SAND INTERCEPTORS

Grease, oil and sand interceptors shall be provided for laundries, restaurants, automobile service facilities, car washes, and other similar facilities. The engineer shall contact the Water Quality Division to determine if an interceptor is required, and which type of interceptor is best suited for the proper handling of liquid wastes. Interceptors shall be installed and maintained by the owner and made accessible to the City. For more details, contact the Water Quality Division.

TRACT AND EASEMENT REQUIREMENTS

All public sanitary sewer lines located outside the public right-of-way or a private street tract must be placed within a minimum twenty (20) feet easement located within a dedicated tract (portion of a utility tract, drainage tract, or open space tract), unless approved otherwise by the Water Resources Department. The sanitary sewer line shall be located a minimum of six (6) feet from the edge of the easement. The easement shall be accessible from a public right-of-way, shall be free of obstructions, shall not be located within a fenced area, and shall be accessible at all times to City service equipment such as trucks, backhoes, etc. Areas in question shall be approved in writing by the Water Resources Department.

9.410

9.411

9.412

Sanitary sewer line easements, located outside of paved areas, shall have a ten (10) foot wide hardened path with a cross-sectional slope not greater than 10%. The hardened path shall consist of native soil compacted to ninety-five (95) percent to a depth of one (1) foot from the existing or design surface, whichever is lower. Any revegetation within the easement will consist of low growing shrubs or plant material acceptable to the Water Operations Division. Trees may be located along the edge of the easement but not within seven (7) feet of the sanitary sewer line as measured to the trunk of the tree.

Locating a public sanitary sewer line on private property within a public utility easement but without dedicating a tract will require written permission from the Water Resources Department.

A copy of any written approval from the Water Resources Department shall be submitted with the final plans.

9.413**EASEMENT ABANDONMENT REQUIREMENTS**

When a property owner or developer believes a sanitary sewer line easement, or portion thereof, is no longer required by the City, an abandonment may be requested by completing and filing an application through the City's One-Stop Shop.

After completing and filing the application, the property owner or developer shall send a letter requesting abandonment of the easement, along with the reason, to the Water Resources Department with the following exhibits attached:

1. A detailed map highlighting the easement to be abandoned and locations of existing water and sewer lines shown in reference to the easement.
2. If existing water and/or sewer lines are to be abandoned, a detailed civil plan prepared by a professional engineer licensed in the State of Arizona must be supplied describing the method of abandonment and any necessary relocations of the water and/or sewer lines.
3. The Water Resources Department will issue a letter recommending approval or denial of the abandonment request and any stipulations that may be required in conjunction with the abandonment.
4. This letter shall be attached to an Application for Release of Easement and will be submitted by the applicant to the One Stop Shop for subsequent processing by Development Services.

Failure to comply with the above process will result in a denial of the request. Where replacement rights are requested by the City, the City will not relinquish existing rights until the replacement rights have been granted.

9.414**PRIVATE SANITARY SEWER LINES**

Private sanitary sewer lines shall meet the Maricopa County Environmental Services Department and the City of Scottsdale Building Inspection Services requirements for approval. Privately owned and maintained sanitary sewer lines shall not be located in the street right-of-way or in a public utility easement.

Wastewater collection systems within commercial properties shall be designed as private system per the Uniform Plumbing Code.

9.415**ALTERNATIVE SANITARY SEWER SYSTEMS**

Developers or property owners may request that the Water Resources Department consider the design of alternative wastewater systems upon their engineer's determination that conventional gravity or forced sanitary sewer systems cannot provide adequate service

to the development. Contact the Water Resources Department for information regarding alternative sewer designs.

If an alternative wastewater system is acceptable to the Water Resources Department, the design concept shall then be coordinated with the Maricopa County Environmental Services Department for their input.

FINAL PLANS PREPARATION

9.500

General Requirements for the preparation of final plans in the City are described in Chapter 3, "General Construction Plan Requirements". This section supplements the requirements of Chapter 3.

A. Ordinance Requirements

Upon development of property for which City wastewater service is desired and available, the developer shall submit a plan for the wastewater system prepared by a professional engineer licensed in the State of Arizona (sec. 49-122).

B. Design Policy

Any variance to these standards will require written permission from the Water Resources Department.

C. Design Standards

Any project specific notes that apply to construction on the City's wastewater system are required on each set of final plans that include improvements to the City's wastewater system or a wastewater system that is to be dedicated to the City.

SPECIFIC SEWER PLAN REQUIREMENTS

9.501

The following paragraphs highlight requirements for the preparation of wastewater final plans that are to be submitted to the City for approval.

1. All sanitary sewer lines shall be shown in both plan and profile and pipe material called out.
2. Each manhole shall have a unique identifier and be labeled in both plan and profile.
3. Sanitary sewer line stationing shall be along the centerline of the pipe.
4. Concrete encasement shall be shown in both plan and profile. The beginning and ending stations of the encasement shall be called out.
5. If a line is to be connected to an existing system, the following note shall be placed on the final plans: "Contractor shall verify the location of the existing sanitary sewer line before proceeding with trenching."
6. Both slope and elevation shall be shown on all proposed sanitary sewer lines stubbed out for future extension.
7. Where sanitary sewer lines cross water lines, storm drains, or drainage culverts, the clearances shall be shown in profile.
8. For permitting purposes, quantities for all items of work within the public right-of-way and public utility easements shall be included on the cover sheet of the final plans.
9. Sanitary sewer service line invert elevations shall be called out for all final plans. All service line connections shall be shown on the final plans with the ends of any capped service lines located by station, offset, or dimension.
10. The drawings shall show all utility locations, sizes, easements, right-of-way, and other structural features affecting the sanitary sewer line.

11. Lift station plans shall show all invert elevations, structural elevations, existing and finished grades, control setting elevations, structural design of the wet well and dry well, valves and piping, surge control devices, pump suction and discharge details and any other details necessary to provide construction of the design.
12. Plans and profiles of force mains shall show size, invert and grade elevations, material, existing and proposed utility locations, and any other necessary details.
13. Private and dry sanitary sewer lines shall be noted as such on the final plans set. The responsibility for operation and maintenance of private sewer systems shall be stated on the final plans.
14. Easements within tracts shall be shown and labeled in plan view. Existing County recording numbers shall be shown on the final plans.
15. All plan documents for sanitary sewer lines and/or wastewater treatment works shall be prepared by a registered civil professional engineer licensed in State of Arizona under the provisions of ARS 32:141-145.
16. Final plans must comply with any design review or preliminary plat stipulations and any accepted wastewater basis of design report.

Additional requirements for the preparation of final plans in the City are presented in Section 3 of the City's Design Standards and Policies Manual.

9.502**REVIEWS AND APPROVALS**

All final plans that include work on the City's wastewater system, or on a system which is to be dedicated to the City, must be submitted to the One Stop Shop for review. Plan review fees must be paid at the time of plan submittal.

No final plans will be submitted unless accompanied by a copy of the accepted basis of design report, when one is stipulated for the project. If master plans or basis of design reports are being submitted as part of a development review board or preliminary plat package, they should also be submitted separately through the One Stop Shop for review by the Water Resources Department.

Maricopa County Environmental Services Department approval is required prior to approval of final plans by Plan Review Services. No permits for improvements to the public wastewater system will be issued until the owner or developer has provided all necessary easements and rights-of-way. These instruments of dedication must be approved and submitted to the City for recording at the Maricopa County Recorder's Office.